



Bruhat Bengaluru Mahanagara Palike


No.BBMP/MOH/PR/34/2020-21

Medical Officer of Health
Bommanahalli Zone
Bengaluru-68.
Date: 17/10/2020

Safe Drinking Water and Sanitary Condition Certificate.

This is to Certify that the "NATIONAL PUBLIC SCHOOL" Located at #81, 3RD Cross, 60ft Road, Uttarahalli, Dr. Vishnuvardhan main road, Banashankari 6th Stage, Bengaluru-560061, Has safe drinking water facilities for the Students and members of staffs of the institution and is maintaining the hygienic sanitation condition in the school building and The campus Maintains as per the norms prescribed by the state Govt. The above valid for a period of 2020-21

The above Certificate is valid till 2020-21


ಅರೋಗ್ಯ ಮತ್ತು ಸ್ವಚ್ಛತೆ ವಿಭಾಗ
Bommanahalli Zone
ಬೆಂಗಳೂರು, Bengaluru-68.
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

To,
Principal
"NATIONAL PUBLIC SCHOOL"
#81, 3RD Cross, 60ft Road, Uttarahalli,
Dr. Vishnuvardhan main road,
Banashankari 6th Stage, Bengaluru-560061,



Lifeguard Laboratories

"Shreya", # 35, 12th Cross, Gayathri Extension, Basaveshwaranagar,
Bengaluru - 560 079. Phone : 080-23226087 Telefax : 080-23236087
Email : qualitytesting@live.com Website : www.lifeguardlabs.com



TEST CERTIFICATE

Sample Submitted By : **National Public School**
Bangalore

No. : 20315
Date : 19.10.2020
Reference No. :

Sample Particulars : Drinking Water

Date of Receipt : 15.10.2020

RESULTS

Reference: Letter 15.10.2020 / Water
Test: Test as per request
Method: AOAC \ BIS methods
Results:
pH: 7.21 (Std 6.5-7.54)
Total Hardness 45 (Max 250mg /ltr)
MPN of Ecoli 21 (Max 120/100ml)
Interpretation The given sample of water is potable;

BIS- Bureau of Indian Standards;
AOAC- Association of Official Analytical Chemists
qualitytesting@live.com

NOTE :

1. Sampling is not done by us.
2. The result listed refer only to the tested samples and applicable parameters. Endorsement of products is neither inferred nor implied.
3. Samples will be destroyed after one month from the date of Issue of test certificate unless otherwise specified.
4. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing .
5. Subject to Bengaluru Jurisdiction.
6. Total liability of our laboratory is limited to the invoice amount.

ANALYST/CHEMIST 
AUTHORISED SIGNATORY 
LIFEGUARD IS A REGISTERED TRADEMARK